

TSTRANSCO Transmission Losses for the month of August 2015					
EBC Data					
	INPUT		OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
<b>TSGENCO</b>	<b>TOTAL</b>	<b>1210.28</b>	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1213.22	TSSPDCL	2939.97	
	HYDEL	-2.94	TSNPDCL	1253.31	
<b>C.G.S</b>			<b>Total</b>	<b>4193.29</b>	
	CGS ( Injection at TS-Periphery)	<b>2866.35</b>			
<b>GPPs</b>	<b>TOTAL</b>	<b>239.13</b>			
	132KV My Home Cements I & II	20.08			
	HWP	6.24			
	Kesoram	2.71			
	NBFA # 1 & 2	39.73			
	Sitapuram Power Limited	13.75			
	Madhucon SPIL 132 kV Kusumanchi	12.09			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	30.36			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	3.16			
	Krishnaveni sugars	13.68			
	132KV Laxmi Tulasi	4.52			
	Orient Cement 132 kV	0.02			
	NBEIL #1	42.98			
	NBEIL #2	43.88			
	ICL (Rassi Cements)	5.27			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	0.67			
<b>Non-Conventional (132 Kv PDs)</b>	<b>TOTAL</b>	<b>14.63</b>			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.08			
	Kakatiya Cement & Sugar Industries Ltd.	-0.11			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Nizam Deccan Sugars Ltd.	-0.14			
	SLS Power Corp. Ltd.	7.38			
	Shravana Power Projects Pvt. Ltd.	3.95			
	Enrich (Solar)	3.69	<b>Losses</b>	<b>MU</b>	<b>%</b>
			With in State	137.10	3.17
	<b>TOTAL INPUT</b>	<b>4330.39</b>	<b>Total Losses</b>	<b>137.10</b>	<b>3.17</b>
* Transmission Losses are applicable to OA Users for the period from 00.00 hours of 26th September 2015 to 24.00 hours of 25th October 2015					
* The Transmission Losses are worked out by using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st August 2015 to 24.00 Hr of 31st August 2015 at 00.30 Hr interval.					
* The SR Losses (External Losses to TSTRANSCO) for the month of August 2015 is 3.0293%					
* Cumulative losses at TS-Periphery FY 2015-16 is 3.19 %					