

TSTRANSCO Transmission Losses for the month of December 2014					
EBC Data					
		INPUT	OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	1336.82	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1163.97	TSSPDCL	2707.79	
	HYDEL	172.85	TSNPDCL	1040.24	
C.G.S			Total	3748.03	
	CGS (Injection at TS-Periphery)	2236.58			
GPPs	TOTAL	253.03			
	132KV My Home Cements I & II	27.44			
	HWP	7.62			
	Kesoram	0.61			
	NBFA # 1 & 2	49.32			
	Sitapuram Power Limited	22.91			
	Madhucon SPIL 132 kV Kusumanchi	12.95			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	27.29			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	2.44			
	Krishnaveni sugars	11.64			
	132KV Laxmi Tulasi	5.06			
	Orient Cement 132 kV	0.71			
	NBEIL #1	40.52			
	NBEIL #2	40.37			
	ICL (Rassi Cements)	4.12			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	0.00			
Non-Conventional (132 Kv PDs)	TOTAL	29.43			
	G.S.R.Sugars Pvt Ltd	4.71			
	Ganapathi Sugars Ltd.	6.85			
	Kakatiya Cement & Sugar Industries Ltd.	6.18			
	Nagarjuna Green Power Ltd. (NGPL)	0.01			
	Nizam Deccan Sugars Ltd.	4.93			
	SLS Power Corp. Ltd.	3.84			
	Shravana Power Projects Pvt. Ltd.	2.89			
			Losses	MU	%
			With in State	107.82	2.80
	TOTAL INPUT	3855.85	Total Losses	107.82	2.80
*Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th Jan 2015 to 24.00'hours of 25th Feb 2015					
* The Transmission Losses are worked out using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st December 2014 to 24.00 Hr of 31st December 2014 at 00.30 Hr interval.					
* The SR Losses (External Losses to TSTRANSCO) for the month of December 2014 is 5.07%					
* Cumulative losses at TS-Peiphery FY2014-15 from June 2014 is 3.24 %					