

TSTRANSCO Transmission Losses for the month of November 2014					
EBC Data					
		INPUT	OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	1326.30	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1150.92	TSSPDCL	2536.55	
	HYDEL	175.38	TSNPDCL	965.03	
C.G.S			Total	3501.59	
	CGS (Injection at TS-Periphery)	2020.38			
CPPs	TOTAL	246.23			
	132KV My Home Cements I & II	26.47			
	HWP	7.51			
	Kesoram	0.94			
	NBFA # 1 & 2	46.81			
	Sitapuram Power Limited	19.84			
	Madhucon SPIL 132 kV Kusumanchi	8.83			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	19.39			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	0.32			
	Krishnaveni sugars	12.03			
	132KV Laxmi Tulasi	5.01			
	Orient Cement 132 kV	0.04			
	NBEIL #1	46.00			
	NBEIL #2	45.47			
	ICL (Rassi Cements)	7.57			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	0.00			
Non-Conventional (132 Kv PDs)	TOTAL	13.33			
	G.S.R.Sugars Pvt Ltd	2.24			
	Ganapathi Sugars Ltd.	2.02			
	Kakatiya Cement & Sugar Industries Ltd.	0.82			
	Nagarjuna Green Power Ltd. (NGPL)	0.01			
	Nizam Deccan Sugars Ltd.	-0.11			
	SLS Power Corp. Ltd.	7.13			
	Shravana Power Projects Pvt. Ltd.	1.22			
			Losses	MU	%
			With in State	104.65	2.90
	TOTAL INPUT	3606.24	Total Losses	104.65	2.90
*Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th Dec 2014 to 24.00'hours of 25th Jan 2015					
* The Transmission Losses are worked out using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st November 2014 to 24.00 Hr of 30th November 2014 at 00.30 Hr interval.					
* The SR Losses (External Losses to TSTRANSCO) for the month of November 2014 is 5.17%					
* Cummilative losses at TS-Peiphery FY2014-15 from June 2014 is 3.31 %					