

TSTRANSCO Transmission Losses for the month of November 2015

EBC Data

INPUT		NET ENERGY in MU	OUTPUT		
			DISCOM	MU	
TSGENCO	TOTAL	1230.85	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1167.35	TSSPDCL	2686.71	
	HYDEL	63.50	TSNPDCL	1060.97	
C.G.S			Total	3747.68	
	CGS (Injection at TS-Periphery)	2361.53			
CPPs	TOTAL	245.42			
	132KV My Home Cements I & II	25.93			
	HWP	6.06			
	Kesoram	0.00			
	NBFA # 1 & 2	49.80			
	Sitapuram Power Limited	20.93			
	Madhucon SPIL 132 kV Kusumanchi	11.79			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	28.29			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	1.53			
	Krishnaveni sugars	11.29			
	132KV Laxmi Tulasi	6.73			
	Orient Cement 132 kV	1.87			
	NBEIL #1	37.39			
	NBEIL #2	36.94			
	ICL (Rassi Cements)	5.87			
	PSR Green Power Proj. Pvt. Ltd.	0.00			
	Deccan cements	1.00			
Non-Conventional (132 Kv PDs)	TOTAL	23.41			
	G.S.R.Sugars Pvt Ltd	1.40			
	Ganapathi Sugars Ltd.	0.47			
	Kakatiya Cement & Sugar Industries Ltd.	6.83			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Nizam Deccan Sugars Ltd.	-0.05			
	SLS Power Corp. Ltd.	6.01			
	Shravana Power Projects Pvt. Ltd.	2.12			
	Enrich (Solar)	6.64	Losses	MU	%
			With in State	113.54	2.94
	TOTAL INPUT	3861.22	Total Losses	113.54	2.94

* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th December 2015 to 24.00'hours of 25th January 2016

* The Transmission Losses are worked out by using MRI data.

* MRI Data considered is from 00.00 Hr of 1st November 2015 to 24.00 Hr of 30th November 2015 at 00.30 Hr interval.

* The SR Losses (External Losses to TSTRANSCO) for the month of November 2015 is 3.125%

* Cumulative losses at TS-Periphery FY 2015-16 is 3.10 %