

TSTRANSCO Transmission Losses for the month of September 2015					
EBC Data					
	INPUT		OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	1106.68	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1083.67	TSSPDCL	2788.92	
	HYDEL	23.01	TSNPDCL	1194.45	
C.G.S			Total	3983.36	
	CGS (Injection at TS-Periphery)	2754.95			
CPPs	TOTAL	230.00			
	132KV My Home Cements I & II	28.42			
	HWP	6.52			
	Kesoram	1.75			
	NBFA # 1 & 2	28.94			
	Sitapuram Power Limited	15.03			
	Madhucon SPIL 132 kV Kusumanchi	10.50			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	30.39			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	2.33			
	Krishnaveni sugars	13.85			
	132KV Laxmi Tulasi	6.58			
	Orient Cement 132 kV	1.78			
	NBEIL #1	37.20			
	NBEIL #2	37.22			
	ICL (Rassi Cements)	8.40			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	1.10			
Non-Conventional (132 Kv PDs)	TOTAL	15.99			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.08			
	Kakatiya Cement & Sugar Industries Ltd.	2.57			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Nizam Deccan Sugars Ltd.	-0.14			
	SLS Power Corp. Ltd.	7.37			
	Shravana Power Projects Pvt. Ltd.	3.14			
	Enrich (Solar)	3.20	Losses	MU	%
			With in State	124.26	3.03
	TOTAL INPUT	4107.62	Total Losses	124.26	3.03
* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th October 2015 to 24.00'hours of 25th November 2015					
* The Transmission Losses are worked out by using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st September 2015 to 24.00 Hr of 30th september 2015 at 00.30 Hr interval.					
* The SR Losses (External Losses to TSTRANSCO) for the month of September 2015 is 2.9522%					
* Cummilative losses at TS-Periphery FY 2015-16 is 3.16 %					