



# TRANSMISSION CORPORATION OF TELANGANA LIMITED

Website: www.tstransco.in. GST No. 36AAFCT0166J1Z9 CIN No. U40102TG2014SGC094248

From:  
The Chief Engineer,  
P&MM, TSTRansco,  
Vidyut Soudha,  
HYDERABAD – 500 082.  
Tel/Fax : 040-23303736

To  
M/s. CG Power and Industrial Solutions Ltd  
Switchgear Division: Power systems,  
A-3, MIDC, Ambad,  
Nashik, Maharashtra – 422010,  
Fax No: 02532381247.

SAP PO.No. 4500003092/CE(P&MM)/SE(P&MM)/DE41/TSPMM41-41/2021/33KV CBs/  
D.No.01/2022, Dt: 01.04.2022.

Sirs,

Sub: Tender Specification No. TSPMM41-41/2021 – Supply of 168Nos. 33 kV Vacuum Circuit Breakers (2000A) – Detailed Purchase Order – Issued – Regarding.

Ref: 1. Tender Specification No. TSPMM41-41/2021.  
2. Your offer against Tender Specification No.TSPMM41-41/2021 on e - platform.  
3. LOI No. CE(P&MM)/SE(P&MM)/DE41/TSPMM41-41/2021/33KV CBs/  
D.No.278/2021, Dt:19.03.2022.

\* \* \*

I, acting for and on behalf of and by the order and direction of TRANSMISSION CORPORATION OF TELANGANA LIMITED, accept the prices offered by you, against Tender Specification No. TSPMM41-41/2021, for supply of equipment detailed in clause (2) below, with the terms and conditions as per the Tender Specification No. TSPMM41-41/2021.

## 1. SCOPE OF CONTRACT

This contract relates to the supply of the equipment detailed in clause –2 below and covers design, manufacture, acceptance testing, dispatch and delivery F.O.R. destination/Stores/site within State of Telangana as detailed in this purchase order.

## 2. SCHEDULE OF EQUIPMENT & PRICES:

(a) Supply of 168Nos. 33kV Vacuum Circuit Breakers (2000A) conforming to latest IEC/IS, complete with Terminal Connectors suitable for twin ACSR Moose conductor and as per Technical specification as per the price break-up indicated below:

All Financial Figures are in Rs.

Sl. No.	Description	33KV Vacuum Circuit Breakers (2000A) (HSN Code: 85352122)
1	Ex-Works	1,99,499.00
2	Packing & Forwarding	inclusive
3	Freight	5,857.00
4	Insurance	82.00
5	Total Taxable Unit Rate	2,05,438.00
6	IGST @ 18% on Ex-Works+ Freight+Insurance	36,978.84
7	<b>Unit FADS Price including Taxes</b>	<b>2,42,416.84</b>
8	Quantity (Nos.)	168
9	<b>Total Amount</b>	<b>4,07,26,029.12</b>
<b>Rupees Four Crores Seven Lakhs Twenty Six Thousand Twenty Nine and Twelve Paise Only.</b>		

- (b) The equipment shall be supplied from your Nasik works. The prices of equipment accepted above are FIRM and FOR delivery destination stores.
- (c) The dispatch of the equipment is by road only. The transit insurance shall include storage cover for 45 days at destination stores.
- (d) It is noted that the prices are with the present rate of IGST @ 18% on the total of Ex-works, Freight and Insurance.
- (e) The TSTransco shall have the right to vary the ordered quantity by +/- 50% at any time during the execution of the order.
- (f) The Price is inclusive of all incidental charges such as packing, forwarding, handling, unloading and other incidentals.
- (g) TCS at prevailing rates is applicable on any payment made (not applicable on ETC charges), if company's aggregate sales consideration during the relevant financial year exceeds Rs.50 Lakhs and total sales, gross receipts or total turnover including GST if any exceeds Rs.10 Crores in the financial year immediately preceding the financial year of subject sales.

The payment of TCS shall be subjected to furnishing of necessary documents. The stipulated conditions are to be verified by the DDOs while processing the bills.

The PAN No. of TS TRANSCO is AAFCT0166J.

**3. DELIVERY:**

To supply

40Nos. within 4 months from the date of Letter of Intent.

40Nos. in 6<sup>th</sup> month from the date of Letter of Intent.

40Nos. in 8<sup>th</sup> month from the date of Letter of Intent.

48Nos. in 10<sup>th</sup> month from the date of Letter of Intent.

**4. PERFORMANCE SECURITY:**

Performance Security for 10% of the contract value i.e. for **Rs. 40,72,603/-** (Rupees Forty Lakhs Seventy Two Thousand Six Hundred and Three Only) with a validity 60 days beyond the date of completion of performance obligations including warranty obligations is to be furnished.

In the event of any correction of defects or replacement of defective material during the warranty period, the warranty for the corrected/replaced material will be extended to a further period of 12 months and the Performance Bank Guarantee for proportionate value will be extended 60 days over and above the extended warranty period. It is entirely your responsibility to extend the validity of this Bank Guarantee to cover the period of guarantee well before its expiry.

**5. Guaranteed Technical Particulars:** The Guaranteed Technical Particulars are enclosed to this Purchase Order. The drawings shall be furnished immediately for approval.

**6. Payment:**

- a) 100% payment will be arranged through PFC/REC/Bank/TSTransco funds within 45 days reckoned from the check measurement date in Form-13.
- b) For Real Time Gross Settlement (RTGS) the details of your Bank Account of areas follows:

(i)	Company Name	M/s. CG Power and Industrial Solutions Ltd
(ii)	Name of the Bank	State Bank of India
(iii)	Branch Address	SBI CAG Chennai Branch, 3 <sup>rd</sup> Floor, Sigapi Achi Building, 18/3, Rukmini Lakshmipathi Road, Egmore.
(iv)	Branch Code	009999
(v)	City	Chennai
(vi)	Account No.	38831345246
(vii)	MICR Code	600002098
(viii)	IFSC Code	SBIN0009999
(ix)	PAN No.	AAACC3840K
(x)	GST No.	27AAACC3840K1ZP

- c) Applicable transaction charges will be recovered from the bill amount for each disbursement on LOA raised by unit officers.
- d) The 100% payment mentioned above is subject to submission of performance security by the supplier as per clause (4) above.
- e) The performance guarantee to be executed in accordance with this specification will be furnished on a stamp paper of value Rs.100/- as per the format indicated in Form-4 of the specification. The Bank Guarantee will be extended if required suitably in accordance with the provisions of Performance Security Clause of the Specification.
- f) If the supplier has received any over payments by oversight or if any amounts are due to the TSTransco due to any other reasons, when it is not possible to recover such amounts under the contract resulting out of this specification, TSTransco reserves the right to collect the same from any other amount due to the supplier and / or Bank Guarantees given by the company due to or with TSTransco.
- g) When the supplier does not at any time, fulfill his obligations in replacing / rectifying etc. the damaged / defective materials in part or whole promptly to the satisfaction of the TSTransco Officers, TSTransco reserves the right not to accept the bills against subsequent dispatches made by the supplier and only the supplier will be responsible for any demurrages, wharfages or damage occurring to the consignments so dispatched.
- h) Any incidental charge such as stamp duty, bank charges etc., shall be to the Supplier's account and any charges in relation there to shall not be included in the bills submitted to TSTransco's Paying Officer through Banks.
- i) All payments will be made in non-convertible Indian Rupees.
- j) The Bank details as above are final and shall not be revoked under any circumstances.

#### **7. RESPONSIBILITY OF THE SUPPLIER FOR LOSS/DAMAGE**

- (a) The supplier is responsible for the safe delivery of the goods in good condition at the destination. He should acquaint himself of the conditions obtaining for handling and transport of the goods to destination and shall include and provide for security and protective packing of the goods so as to avoid damage in transit.
- (b) External damages or shortages that are prima-facie the results of rough handling in transit or due to defective packing will be intimated within a fortnight of the receipt of the materials. Internal defects, damages or shortages of any internal parts which cannot ordinarily be detected on a superficial visual examination will be intimated subsequently.

In either case, the defective or damaged materials should be replaced by the supplier free of cost to the TSTransco. If no steps are taken within 15 days of receipt of intimation of defects or such other reasonable time as the TSTransco may deem proper to afford, TSTransco may without prejudice to its other rights and remedies cause to be repaired or rectified the defective material or replace the same and recover the expenditure incurred there for from the deposit such as Earnest Money, Security and Performance or other monies available with TSTransco or by resorting to legal action.

- (c) For the purpose of any legal consideration, the material shall be deemed to pass into TSTransco's ownership only at the final destination where they are delivered and accepted.

**8. Penalty for Late Delivery:**

- a) The delivery period as per agreed delivery schedule shall be deemed to be the essence of the contract. In case of delay in delivery of materials beyond the agreed delivery schedule or to perform the services within the period specified in the contract whatever be the reason the TSTransco may at its option, demand and recover from the supplier from the contract price, as liquidated damages, a sum equivalent to 0.5% per week on the undelivered portion subject to a maximum of 5% of total value of contract.
- b) For penalty, the number of days of delay would be rounded off to the nearest week and penalty calculated accordingly.
- c) Equipment which is not of acceptable quality (or) not confirming to specification would be deemed to be not delivered.
- d) The penalty specified will be levied and would be adjusted against subsequent pending bills.
- e) The check measurement date in Form-13 i.e., the date of receipt of equipment at the destination stores in good condition will be taken as date of delivery.

**9. Force Majeure:**

- a) The Supplier will not be liable for forfeiture of its performance security, penalty for late delivery or termination for default if and to the extent that it's delay in performance or other failure to perform its obligations under the Contract is the result of an event of Force Majeure.
- b) For the purpose of this clause 'Force Majeure' means an event beyond the control of the Supplier and not involving the Suppliers' fault or negligence and not foreseeable. Such

events may include but are not restricted to wars or revolutions, fires, floods, epidemics, earth quakes, Tsunami, quarantine restrictions and freight embargoes.

- c) If the Force Majeure situation arises, the supplier will promptly notify the Purchaser in writing of such condition and the cause thereof. Unless otherwise directed by the Purchaser in writing, the Supplier will continue to perform its obligations under the Contract as far as is reasonably possible, and will seek all reasonable alternative means for performance not prevented by the Force Majeure event.

**10. Termination for Default:**

- (a) The Purchaser without prejudice to any other remedy for breach of Contract, by written notices of default sent to the Supplier, may terminate this Contract in whole or part :
  - i) If the Supplier fails to deliver any or all of the Materials/equipment within the period(s) specified in the Contract, or within any extension thereof granted by the Purchaser.
  - ii) If the Supplier fails to perform any other obligation(s) under the Contract.
  - iii) If the Supplier, in the judgment of the Purchaser has engaged in corrupt or fraudulent practices in competing for or in executing the Contract.
- (b) In the event the Purchaser terminates the Contract in whole or in part, the Purchaser may procure, upon such terms and in such manner, as it deems appropriate, Materials/equipment or services similar to those undelivered and the Supplier will be liable to the Purchaser for any excess costs for such similar Materials/equipment or Services. However, the Supplier will continue performance of the Contract to the extent not terminated.

**11. Termination for convenience:**

- (i) The Purchaser, by written notice sent to the Supplier, may terminate the Contract, in whole or in part, at any time for its convenience. The notice of termination will specify the termination is for the Purchaser's convenience, the extent to which performance of the supplier under the Contract is terminated, and date upon which termination becomes effective.
- (ii) However the Materials / equipment that are complete and ready for shipment within thirty (30) days after the supplier's receipt of notice of termination will be accepted by the Purchaser at the Contract terms and prices.

**12. Warranty:**

The material shall be guaranteed for satisfactory performance for a period of 18 months from the date of receipt of material/equipment at TLC stores or at site in good condition against defects proved to be due to faulty design of material/ workmanship. If during this period, any of the material is found defective they shall be repaired or replaced by you free of all costs to the TSTransco. To and fro freight charges shall also be to your account only.

**13. Taxes:**

Taxes as indicated in the price schedule at para (2) are applicable. You shall agree, that if, at any time, any GST reported to have been paid has not been paid, or a lesser amount has been paid, or on subsequent adjudication or appeal or revision it is decided that a lesser amount is payable, you shall refund such amounts irrespective of time lag.

**14. Statutory Variations:**

Any variation up or down in statutory levy or new levies introduced after tender calling date this specification will be to the account of TSTransco, provided that in cases where delivery schedule is not adhered to by the supplier and there are upward variation/ revision after the agreed delivered date, the supplier will bear the impact of such levies and if there is downward variation / revision the TSTransco will be given credit to that extent.

Statutory variation if any allowed, it is allowed only once during delivery period, i.e. at the time of delivery of goods at factory. In case of sub-vendor items, taxes & duties are inclusive in tender price and no statutory variation is applicable.

In cases where the bidder assumes less tax rates and become lowest, upward variation of taxes will not be considered. In case of the bought out items for which the prices are quoted all-inclusive of taxes, statutory variation shall not be applicable.

**15. Dispatch Instructions:**

The dispatch instructions for the equipment will be issued after inspection/satisfactory routine/acceptance tests results. The prices indicated in clause (2) above shall remain unaltered whatever be the destination.

**16. Inspection:**

After completion of manufacture of the equipment/ material, routine tests shall be performed as per relevant standards and requisite copies of test certificates shall be furnished to the purchaser. Various components of the equipment shall be routine tested in accordance with approved standards and manufacture standards.

As soon as the material/ equipment are ready the supplier will duly send intimation to TSTransco by post/fax and carry out the tests in the presence of the representative of TSTransco. The Supplier shall give at least 15 days advance intimation to enable the Purchaser to depute his representative for witnessing acceptance and routine tests. All charges in connection with inspection shall be borne by the supplier.

The equipment should not be dispatched without final inspection of the tests, approval of test certificates and issue of specific dispatch instructions or specific waiver thereof from this office. The equipment shall reach the destination store/site within three weeks of issue of Dispatch Instructions.

**17. Contract Drawings:**

Approval by TSTransco to the supplier's drawings shall not relieve the supplier of his responsibility for correctness thereof or from results arising out of error or omission therein or from any obligation or liability under the contract. Any supplementary drawings necessary to permit the complete design of the installation prior to receiving the equipment shall also be supplied. Within two weeks of approval, six sets of all approved drawings and soft copy of drawings shall be furnished. One set of drawings and instruction manuals along with soft copy shall be sent along with each equipment at the time of dispatch. Copies of the drawings and manuals shall also be sent to other offices as indicated below.

Consignee	:	One set of approved drawings per consignee
Two Sets	:	Concerned Executive Engineer
To this office	:	Three sets.

**18. Erection, Operation & Maintenance Manuals:**

Erection, operation and maintenance manuals along with soft copy shall be supplied as per distributions given below giving detailed instructions with illustrations along with the equipment. They shall contain clear recommended schedule of maintenance for the guidance of the operating staff. Any items requiring the special attention of the operation engineer should be highlighted.

Consignee	:	One set per consignment
Concerned Executive Engineer	:	Two sets
To this office	:	One set

These shall be sent to the Divisional Engineers / Executive Engineers concerned.



**19. Completeness of Contract:**

All minor accessories that are normally necessary for satisfactory and efficient operation of the equipment shall be supplied by you free of cost to the TSTransco whether these are specifically mentioned or not in the specification, your tender schedules or in this purchase order and the equipment shall be complete in itself.

**20. General Conditions of Contract:**

Except in so far as it is provided otherwise in this contract, you shall abide by the terms and conditions appended to the specification. Except as specifically accepted in this order the terms and conditions mentioned in your quotation under reference are not accepted.

**21. Risk:**

The risk in the property is entirely yours till the goods are received in good condition at the destination.

**22. Packing:**

Each equipment shall be securely packed separately in such a manner as to withstand rough handling during rail and road transit upto site and as per latest IS/BSS/IEC.

**23. Material & Workmanship:**

All the materials shall be of the best class and shall be capable of satisfactory operation in the tropics under service conditions without distortion or deterioration. No welding or filling or plugging of defective parts shall be permitted, unless otherwise specified they shall conform to the requirement of the appropriate Indian, British or American standards (where a standard specification covering the material in question has not been published the standards of the American society for testing of materials should be followed).

The entire design and construction shall be capable of withstanding the several stresses likely to occur in actual services and of resisting rough handling during transport.

**24. Insurance:**

As insurance charges are included in your prices you should cover the equipment against transit risks and also for further period of 45 days towards storage from the date of receipt of equipment at site. It is entirely your responsibility for arranging the insurance through your underwriters. The damages and shortages will be intimated to you as stipulated in purchase order and you shall arrange for replacement/repairs immediately without awaiting settlement from insurance authorities.

**Note:** The material will not be taken into stock unless documentary evidence for Freight and Insurance is furnished along with material.

**25. Interchangeability:**

All similar equipment and removable parts of similar equipment shall be interchangeable with each other.

**26. Spares:**

You shall supply any spares required for the equipment that will be supplied under this order, whenever called upon to do so at fair prices and at the TSTransco's standard terms of payment within a period not exceeding the deliveries accepted therein.

**27. Progress Reports:**

You shall furnish the program of works and progress reports on the manufacture of equipment to this office every month in triplicate till the supplies are completed.

**28. Correspondence:**

- a) Your acknowledgement of this order and all correspondence of general or technical nature shall be addressed to the Chief Engineer/P&MM, TSTransco, Vidyut Soudha, Hyderabad –500 082.
- b) All correspondence regarding dispatches, payments and any other field matters shall be addressed to the concerned paying officer. Copies of such correspondence shall be marked to the concerned Superintending Engineer and to the Chief Engineer/P&MM, TSTransco, Vidyut Soudha, Hyderabad –500 082. Copies of the correspondence regarding payments should also be marked to the Executive Director/Finance, TSTransco, Vidyut Soudha, Hyderabad –500 082.
- c) You shall submit invoices for materials directly to the paying officer.

**29. Jurisdiction:**

All and any disputes or differences arising out of or touching this order shall be decided only by courts or tribunals situated in Hyderabad or Secunderabad cities. No suit or other legal proceedings shall be instituted elsewhere.

**30. Supervision of erection, testing and commissioning:**

You have to provide services of qualified personnel for supervision of erection, testing at site and commissioning of the equipment wherever required. The above services, if requested for, should be provided at free of Cost.

**31. Guarantee for Interrupter:**

You shall give specific guarantee for Interrupter for a period of five years from the date of supply or commissioning (whichever is later) of the 33kV Vacuum Circuit Breakers.

If the Interrupter fails within five years from supply or commissioning (whichever is later), free replacement shall be arranged within seven days of intimation of failure.

If the replacement is not made within seven days, the cost shall be recovered from your running bills or shall be made good by you.

**32. Acknowledgement:**

Please acknowledge the receipt of this purchase order with your confirmation of its acceptance by you and the extra copy enclosed may please be returned with your signature in token of your acceptance.

Encl: GTP.

Yours faithfully,

Chief Engineer/P&MM  
(Acting for and on behalf of TSTRANSCO)

WE ACCEPT THE TERMS AND CONDITIONS OF THIS PURCHASE ORDER

SIGNATURE OF THE CONTRACTOR  
WITH SEAL AND DATE

Copies to:

The Chief Engineer/Transmission/TSTransco/Vidyut Soudha/Hyderabad.\*

The Superintending Engineer/Transmission/TSTransco/Vidyut Soudha/Hyderabad.

The Superintending Engineer/OMC/Metro-Central/TSTransco/2<sup>nd</sup> Floor, 132kV NIMS GIS SS premises/Erramanzil/Panjagutta/Hyderabad -82

The Superintending Engineer/Quality Control/TSTransco/Vidyut Soudha/Hyderabad.

The Executive Director/Finance/TSTransco/Vidyut Soudha/Hyderabad.

The SAO/Pay & accounts/TSTransco/Vidyut Soudha/Hyderabad along with Form-40.

The SAO/Metro-Central/TSTransco/2<sup>nd</sup> Floor, 132kV NIMS GIS SS premises/ Erramanzil/ Panjagutta/Hyderabad -82.

The Divisional Engineer/Transmission & Stores/Metro/Erragadda/ Hyderabad, 500 045.

The AEE/Construction Stores/TSTransco/Erragadda/Hyderabad.

\* Copy of this PO is available on <http://www.tstransco.in/>

## Annexure

### GUARANTEED TECHNICAL PARTICULARS

S.No.	Description	CG Power and Industrial Solutions Limited.
1 a)	Maker's name country of manufacture.	CG Power and Industrial Solutions Limited, Nashik, Maharashtra.
b)	Manufacturer's type designation.	36PV25A
2	Applicable Technical Standards	IEC62271-100 / IS:13118
3 a)	Rated voltage (kV)	36
b)	Rated Frequency (Hz)	50
4	Number of Poles	3
5.a)	Class (Outdoor/Indoor)	Outdoor
b)	Class C2/Class M2	C2, M2
6	Rated normal current:	
a)	Under site conditions (Amps)	2000
b)	Rated (Amps)	2000
7	Rated short circuit breaking current:	
a)	R.M.S. value of AC component of rated short circuit current (kA)	25
b)	Percentage DC component	<50% DC component
c)	Asymmetrical breaking current (including DC component)	As per IS: 131181/1991/IEC-62271-100
d)	Certificate or report no.	HPL17142
e)	Oscillogram no.	HPL17142
8	Rated short circuit making current (kA)	62.5kA
9	First Pole to clear factor	1.5
10	Rated transient recovery voltage for terminal faults (kV peak)	43kVp
11	Rated characteristics for short line faults.	Short line breaking current 19.73kA
12	Rated operating sequence .	O-0.3 Sec-CO-3min-CO
13	Rated duration of short circuit (sec.)	3 Sec
14	Rated out of phase breaking current (kA)	6.46kA
15	Opening time (ms)	<40ms
16	Arcing time (ms)	
a)	At 10% rated breaking current	<20ms max
b)	At 25% rated breaking current	<20ms max
c)	At 50% rated breaking current	<20ms max
d)	At 100% rated breaking current	<20ms max
e)	Maximum Arcing time at lowest fault currents	<20ms max
17	Break time (ms)	
a)	At 10% rated breaking current	60 ms max

<b>S.No.</b>	<b>Description</b>	<b>CG Power and Industrial Solutions Limited.</b>
b)	At 25% rated breaking current	60 ms max
c)	At 50% rated breaking current	60 ms max
d)	At 100% rated breaking current	60 ms max
e)	Maximum break time at lowest fault current	60 ms max
18	Closing time (ms)	100ms max.
19	Maximum Pole discrepancy time:	
a)	Opening (ms)	Not applicable as breaker offered is of gang operated type
b)	Closing (ms)	Not applicable as breaker offered is of gang operated type
20	Rated line charging breaking current (kA)	10A
21	Maximum cable charging current	
a)	On supply side	50 A
b)	On line side	50 A
22	Rated small inductive breaking current (kA)	NA
23	Max. rise of temperature over ambient temperature for current rating under clause 6.	Within limits of IS:13118/1991/IEC 62271-100
24	Interrupting capacity based on duty cycle	
a)	AC Component (kA)	25kA for 3 Sec
b)	Percentage D.C. Component	<50% DC component
25	Latching current (kA)	Not Applicable
26	No of breaks in series per pole	one
27	Length of contact travel (mm)	17 (+1,-1)mm
28	Total length of break per pole (mm)	17 (+1,-1)mm
29	Rate of contact travel :	
a)	At tripping (meters/sec.)	1.1 to 1.6
b)	At closing (meters/sec.)	0.7 to 1.3
30	Type of devices, if any, used to obtain uniform voltage distribution between breaks	NA (Single break)
31	Recovery voltage distribution between breaks in percent of rated voltage:	
a)	Single line to ground fault	48.9kVp
b)	Interruption of short lines	L75 test duty – TRV – 42.5kVp
c)	Switching off an unloaded Transformers	NA
32	Type of main contact	BUTT type
33	Type of arcing-contacts and/or arc control device	NA for VCB

<b>S.No.</b>	<b>Description</b>	<b>CG Power and Industrial Solutions Limited.</b>
34	Material of contacts	
a)	Main	Copper chromium alloy
b)	Arcing	NA for VCB
c)	Auxiliary	copper alloy
35	Whether contacts are silver plated	Main contacts not silver plated and aux. contacts silver plated
36	Thickness of silver coating (mm)	8-12Microns
37	Contact pressure (kg/sq. mm.)	220Kgf
38	Insulation level of the breaker :	
a)	1 minute power frequency withstand voltage (kV rms)	70kV (rms)
b)	Switching surge withstand test voltage (kV peak)	NA
c)	Impulse withstand test voltage (kV peak)	170kVp
d)	Max. dynamic p.f. over voltage withstand (kV peak)	NA
39	Minimum clearance in Air (mm)	
a)	Between Phases (live parts)	420mm
b)	Between live parts and earth	380mm
c)	Centre to centre distance between phases	700mm
d)	The safety boundaries during a breaking operation for circuit breakers with an external exhaust for ionized gases or flames	Not Applicable
40	Whether the circuit breaker is suitable for fixed trip operation or trip free operation and whether it is provided with a lock-out device preventing closing of the breaker	Trip free, lock out device not applicable
41	Method of closing	
a)	Normal	mechanical / electrical
b)	Emergency	Mechanical ON/OFF
42	Type of closing mechanism	Motorized spring closing mechanism
43 a)	Normal voltage of closing	220V DC
b)	Pick up range, (volts)	190V DC to 240V DC
44 a)	Normal voltage of closing	220V DC
b)	Pick up range, (volts)	190V DC to 240V DC
c)	Power at normal voltage of closing mechanism, (watts)	200 Watt Approx.
d)	Power at 85% of normal Voltage (watts)	200 Watt Approx.
45	Type of tripping mechanism	Spring - Spring

<b>S.No.</b>	<b>Description</b>	<b>CG Power and Industrial Solutions Limited.</b>
46	Normal voltage of tripping coils, (volts)	220V DC
47 a)	Power at normal voltage for tripping coils, (watts)	200 Watt Approx.
b)	Power at 70% normal voltage for tripping coils, (watts)	200 Watt Approx.
48	Arc duration at 100% (ms) Interruption capacity:	
a)	i) Opening Arcing time No. of loops and time including resistor current duration (cycle)	Not applicable since concealed Vacuum Interrupter
	ii) Resistor current duration, (cycle)	
	iii) Total length of the arc, (mm)	
	iv) Max. length of the arc, (mm)	
	v) Total interrupting time measured from instant of trip coil energisation to arc extinction of resistor current (cycles).	
b)	Closing time measured from instant of application of power to closing device upto arcing contacts touching, (cycles).	
49	Critical current (current giving the longest arc when a break takes place) (kA)	NA
50 a)	Recovery voltage when circuit breaker tested at 100% rated breaking capacity, (kV inst.)	48 to 54kVp
b)	Rate of rise of re-striking voltage at breaking	
i)	for 30% breaking capacity, (kV/Micro. sec.)	0.57
ii)	for 100% breaking capacity, (kV/Micro. sec.)	0.57
c)	Maximum over voltage factor of the circuit breaker when switching off.	NA
i)	Unloaded transformers.	
ii)	Loaded transformer	
iii)	Open circuited lines	
51	When switching of synchronous systems:	
a)	Max. current (kA)	25kA
b)	Max. contacts of 1 pole (kV)	78.6kVp

<b>S.No.</b>	<b>Description</b>	<b>CG Power and Industrial Solutions Limited.</b>
52	No. of openings the circuit breaker is capable of performing without inspection, replacement of contacts or other main parts.	
a)	at 50% rated current	10000
b)	at 100% rated current	7000
c)	at current corresponding to 50% rated breaking capacity	90
d)	at current corresponding to 100% rated breaking capacity	20
53 a)	Weight of complete circuit breaker (kg.)	500 kg (approx)
b)	Impact loading for foundation design, to include dead load plus impact value on opening at maximum interrupting ratings, in terms of equivalent static load, (kg.)	600 kg
c)	Overall dimensions:	
	Height (mm)	3483
	Width (mm)	450
	Length (mm)	1800
54	Porcelain:	
a)	Make	Jaipur glass/Ravi Kiran/ CJI/ABI/Modern
b)	Type	Porcelain/Hollow
c)	Descriptive pamphlet	-
d)	Weight (kg.)	22 kg Approx
e)	Transport dimensions (mm)	W 1900mm x H 3683mm x D 600mm
f)	Height above floor, required to remove porcelain, (mm)	3646 mm +/-10%
g)	Insulation class	Class C
h)	One minute dry power frequency withstand kV (r.m.s.)	70
i)	10 seconds wet power frequency withstand kV (peak)	70
j)	Flash over voltage (kV)	>70
k)	Full wave impulse withstand voltage kV (peak)	170
l)	Switching surge withstand voltage kV (peak)	NA
m)	Corona discharge voltage, (kV r.m.s.)	NA
n)	Nature of the dielectric	Porcelain
o)	Creepage distance total protected (mm)	900



S.No.	Description	CG Power and Industrial Solutions Limited.
p)	Volume of insulating medium per porcelain (liters)	7.71
q)	Permissible safe cantilever loading on installed porcelain (kg.m.)	As per IEC:2099:1986, 600Kg
55	Operating mechanism :	
a)	a) Mechanically operated or pneumatically or hydraulically operated.	Mechanically operated
b)	For stored energy mechanism :	
1	Spring charging motor	
i)	Rating kW	450 Watt (Approx.)
ii)	Voltage V	230 V AC
iii)	Power frequency withstand voltage kV.	2kV / 1 min
iv)	Time required for the motor to charge the spring fully (secs.)	<15 ms
v)	Power required at the normal control voltage to charge the spring - Watts.	450 Watt (Approx.)
vi)	Specification reference.	IS: 996
2	Spring closing/opening	
i)	Number of springs	Closing 2Nos / Opening 2Nos
ii)	Type	Helical
iii)	Number of turns	Closing 15.5 / Tripping 33.25
iv)	Guage	Closing 10mm and tripping 5mm (diameter)
v)	External diameter mm.	66mm and 26.3mm
vi)	Stiffness	4.25kg/mm and 2kg/mm
vii)	Material	Cold drawn steel wire
viii)	Force developed in full charged position.	340kg and 155kg
ix)	Specification reference.	IS 7907/1976
56	Details of Vacuum for 33kV VCBs	
a)	Make of the vacuum bottle/interrupter	Crompton Greaves Ltd
b)	Pressure maintained in the vacuum interrupter	10 <sup>-6</sup> Torr
c)	Gap between the contacts in vacuum	17 (+1,-1)mm
d)	Area of contacts	1761 Sq mm
e)	Allowable increase in the Vacuum interrupter	NA
f)	Measure, if any, to be taken for maintaining normal allowable pressure in the vacuum interrupter	No, Vacuum interrupter to be replaced after contact erosion exceeds specified limits of 3mm
g)	Periodically maintenance of the following	

<b>S.No.</b>	<b>Description</b>	<b>CG Power and Industrial Solutions Limited.</b>
i)	For maintaining vacuum interrupting chamber	No, Vacuum interrupter to be replaced after contact erosion exceeds specified limits of 3mm
ii)	for changing contacts	Periodic lubrication of mechanism moving parts required
iii)	other maintainable schedules if any	None
h)	method of checking pressure in vacuum interrupter and procedure to check up	Power frequency high voltage test
57	No. of auxiliary contacts provided	
a)	Those close when breaker is closed.	12
b)	Those open when breaker is closed.	12
c)	Those adjustable with respect to the position of main contacts.	not adjustable
d)	Continuous rating of contacts.	10A at 220V DC
e)	Breaking capacity of contacts.	25A

Chief Engineer/P&MM

This order is placed against the indents indicated below:

Sl. No.	Indent Reference	Qty (Nos.)	Required for
1	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-2/ F.TR.SS.A2.6884/19/ D.No.418/20, Dt.06.11.2020	1	Augmentation at 132kV Donthanpally SS
2	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-2/ F.TR.SS. A2.6884/19/ D.No.442/20, Dt.19.11.2020	1	Augmentation at 132kV Khaithalapur SS
3	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-3/F. SKagaznagar2588/20/D.No.593/20, dt:19.01.2021	1	Shifting of 33kV Bus and 33kV feeder bay at 132/33kV Sirpurkagaznagar SS.
4	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-2/ F.TR.SS.A2.199/20/D.No.644, dt:08.02.2021	1	Augmentation at 132kV SS Mylardevpally.
5	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-3/ F.Manoharabad-4647/20/D.No.649/20, dt:13.02.2021	2	Replacement of old equip at 132/33kV Manoharabad SS
6	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-3/ F.SRMply-4122/20/D.No.789/20, dt:31.03.2021	1	Shifting of 6Nos. 33kV feeders at 220kV Shivarampally SS
7	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-2/ F.TR.SS.A2.4804/20/D.No.34,dt:19.04.2021	1	Augmentation at 132kV Pashmailaram SS
8	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-2/ F.1973/2018/D.No.74/21,dt:30.04.2021	1	Erection of 1Nos. New bays for TSNPDCL at 132kV SS Dasnagar DC work.
9	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-2/ F.2957/18/ SAP WBS Elements/D.No.75/21, dt:30.04.2021	1	Erection of 1Nos. 33kV bays for BTPS Pump House at 220kV SS Manuguru DC work.
10	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-2/ F.5340/2021/ 4 bays at SRPLY/ D.No.76/21,dt:30.04.2021	4	Erection of 4Nos. New bays for TSSPDCL at 220kV SS Shivarampally DC work.
11	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-2/ F.TR.SS. A2.6240/21/D.No.91/21, dt:11.05.2021	1	Augmentation works at 132kV Mamidipally SS, 132kV Jadcherla SS, 132kV Munagala SS, 132kV Domakonda SS, 132kV Godur SS.
12	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-3/ F.Bandlaguda /D.No.163/21, dt:19.06.2021,	6	Shifting of 9 Nos 33kV feeders at 132/33kV Bandlaguda SS.
13	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-1/ F.Rolling Stock 21-22/ D.No.203/21, dt:07.07.2021	125	Rolling stock FY:2021-22
14	U.O.No.CE(Tr)/SE(Tr)/DE-SS/ADE-2/ F.1312/21/D.No.360/21, dt:30.08.2021,	1	Erection of 1No. 33kV Bay for Singereni Collieries at 132kV Penubally SS under DC work.
15	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-4/F.Diversion of materials 33kV bays/ D.No.515/21, Dt.12.11.2021.	4	Erection of 33kV New Bays at 132kV SS Narmetta, 132kV SS Palakurthy, 132kV SS Dharmasgar and 220kV SS Weddekothapally under DC works.
16	U.O.No.CE(Tr)/SE(Tr)/DE(SS)/ADE-2/F.132/33kV Aug/D.No.582/21, Dt.08.12.2021.	14	Augmentation of 132/33kV PTR capacities at 13Nos. Substations.

Sl. No.	Indent Reference	Qty (Nos.)	Required for
17	U.O.No.CE(Tr)/SE(Tr)/DE-SS/ADE-2/ F.6841/21/D.No.735/21, Dt.05.02.2022	1	For erection of 1No. 33kV Bay for M/s. Raghram Synthetics Pvt Ltd at 132kV Suglampally SS under DC works.
18	U.O.No.CE(Tr)/SE(Tr)/DE-SS/ADE-2/ F.82/22/D.No.759/21, Dt.17.02.2022	1	For erection of 1No. 33kV Bay for SCCL R&R colony at 132kV Manthani SS under DC works.
19	U.O.No.CE(Tr)/SE(Tr)/DE-SS/ADE-2/ F.19/22/D.No.787/21, Dt.24.02.2022	1	For supply and erection of 1No. 33kV Bay for diversion of loads in Bhadradri Kothagudem dist at 132kV B.Gangaram SS under DC works.
Total		168	