



**TRANSMISSION CORPORATION OF TELANGANA LIMITED**  
**VIDYUT SOUDHA :: HYDERABAD – 500 082. Off: PABX:040-23396000**  
**Website:www.tstransco.in CIN No:U40102TG2014SGC094248**

Erection of 500MVA ICT in place of failed 315 MVA ICT at 400kV Mamidipally SS for an amount Rs **2576.95 Lakhs.** – Administrative Approval - Regarding.

-----

**T.O.O. CE (Transmission) Ms. No. 1349**

**Dt. 25 . 03 .2022.**

**Read the following**

**ORDER:**

On 24.06.2021 at 19-25 Hrs 400/220 KV 315 MVA (YOM 1998) CGL make ICT –I failed at 400 KV SS Mamidipally.

2) In view of CEA recommendations to consider 500 MVA ICTs in 400 KV substations for optimum utilization and for meeting increasing load growth in the vicinity of scheme area, the Chief Engineer/ Metro zone furnished the estimate towards erection of 500MVA ICT in place of failed 315 MVA ICT at 400kV Mamidipally SS with estimated cost of Rs. **2576.95 Lakhs** including contingencies, establishment and other overhead charges.

3) After careful examination, TSTRANSCO accords approval for Erection of 500MVA ICT in place of failed 315 MVA ICT at 400kV Mamidipally SS for an amount Rs **2576.95 Lakhs.**

- i) The Chief Engineer/Transmission shall submit investment proposal to obtain approval from the Hon'ble TSERC.
- ii) The Chief Engineer/Metro zone is authorized to take up the works after investment approval from the Hon'ble TSERC. by calling tenders, as per the delegation of powers in vogue.
- iii) The FA&CCA(Accounts) & CFO shall arrange budget from internal sources.
- iv) The Chief Engineer/P&MM shall procure 400/220 KV 500 MVA ICT.
- v) The Chief Engineer/400 KV shall arrange required associated equipment like Lightning Arrestors, CTs, Insulators and other material by including in upcoming or ongoing 400 KV projects.

4) This order is issued with the concurrence of the Joint Managing Director (Fin., Comml. & HRD) vide Regd. No. 1297 , Dt: 22 . 03 .2022.

**(BY ORDER AND IN THE NAME OF TRANSMISSION CORPORATION OF TELANGANA LIMITED)**

**D. PRABHAKAR RAO**  
**Chairman & Managing Director**

Contd...2

**To**

The Chief Engineer/ Transmission/ TSTRANSCO/Vidyut Soudha/Hyderabad.

The Chief Engineer/P &MM/TSTRANSCO/Vidyut Soudha/Hyderabad.

The FA & CCA (Accounts) /TSTRANSCO/Vidyut Soudha, Hyderabad.

The Chief Engineer/400KV/ TSTRANSCO.

The Chief Engineer/Construction Zone/ TSTRANSCO

The Chief Engineer/ Metro Zone/ TSTRANSCO

**Copy to:**

The Chief Engineer/Comml., &RAC/TSTRANSCO/Vidyut Soudha/ Hyderabad.

The Chief Engineer/SLDC/TSTRANSCO/Vidyut Soudha/ Hyderabad.

The Chief Engineer /Civil /TSTRANSCO/Vidyut Soudha/Hyderabad.

The Superintending Engineer/Construction/Vidyut Soudha/Hyderabad.

The Superintending Engineer/Schemes& Designs/Construction/Vidyut Soudha/Hyderabad

The Superintending Engineer/Power Systems/TSTRANSCO/Vidyut Soudha/ Hyderabad.

The Superintending Engineer/P&MM/TSTRANSCO/Vidyut Soudha/Hyderabad.

The Superintending Engineer /OMC/ Circles /TSTRANSCO.

The Superintending Engineer /Civil /TSTRANSCO/Vidyut Soudha/Hyderabad.

The SE (Technical) to CMD/TSTRANSCO/Vidyut Soudha / Hyderabad.

The DE(Technical) to Director / Projects / TSTRANSCO/Vidyut Soudha/ Hyderabad

The DE(Technical) to Director (Transmission)/TSTRANSCO/ Vidyut Soudha/ Hyderabad.

The ADE/(Technical) to Director (LIS)/TSTRANSCO/Vidyut Soudha/ Hyderabad.

The AE (Technical) to Director/ Grid Operation/TSTRANSCO/Vidyut Soudha/ Hyderabad.

PA to JMD(Fin. Comml,& HRD)/TSTRANSCO/ Vidyut Soudha/ Hyderabad.

**Current File:CE(Tr)/SE(Tr)/DE(SS)/ADE-2/File No. 6719 /21/ D.No. 865 /21, Dt: 25 .03.2022**

---

**Energy saved is energy produced // Electricity saved is electricity produced**

