

TRANSMISSION CORPORATION OF TELANGANA LIMITED

Sub: Cancellation of certain Administrative Approvals - Reg.

T.O.O (CE-Construction) Ms.No. 1918

Dated:29.02.2024.

Read the following

O R D E R

TSTRANSCO accorded the following administrative approvals and propose to cancel these administrative approvals due to following reasons. The details of administrative approvals are as follows.

Sl. No.	Name of the Scheme	T.O.O. Details	Amount (in lakhs)	Reasons for cancellation
Substations				
1	Erection of 132/33 KV Substation at Raparthy Village of Kalher Mandal of Medak District	MS.No.189, Dt:23.09.2015	2171.00	At present the 33kv substations loads in and around Raparthy can be fed from both pedda shankarampet and Narayankhed 132/33kV Substations without any problem.
2	Erection of 220/132/33kV Substation at Kachavani Singaram in Ghatkesar Mandal of Ranga Reddy District along with connected lines.	MS.No.45, 31.03.2016	4604.00	As T.O.O is issued for 220/33kV CPRI SS which will feed the scheme area. Hence, now it is not required
3	Erection of 132/33KV IDA Mallapur Sub-station in Medchal-Malkajgiri District.	MS.No.30, 27.02.2017	1905.00	As 132kV ZTS Moulali SS is nearer to IDA Mallapur premises which is feeding the same scheme area. Hence, now it is not required
4	Erection of 132/33kV Sub-Station at Puttandoddi (V), Itikyal (M), Mahaboobnagar District.	MS.No.75, 19.05.2017	1376.00	As present loads are catered by existing network. Hence now it is not required
5	Providing of 132 kV features at existing 220/33 kV Sub Station Nagaram in Warangal Urban District	MS.No.1212 07.10.2021	5897.91	As the work covered under bulk load works of Railways. Now it is not necessary.
6	Erection of 132/33kV Sub-Station at Jainath (M) in Adilabad District.	MS.No.1800, 22.09.2023	2713.00	As present loads are catered by existing network. Hence now it is not required

Contd..2

	Lines			
1	providing second source of supply to 132/33KV SS Karimnagar in Karimnagar District	MS.No.45 23.03.2017	440.00	Making LILO of one circuit of 132 kV Durshed-Sircilla DC Line at 132 kV Karimnagar Sub-Station is not possible due to city development and increased load will be met by converting the existing 132kV line from Durshed to Karimnagar to the HTLS.

2. After careful consideration, TSTRANSCO cancels the above administrative approvals.
This authorization is issued with the concurrence of Joint Managing Director (Fin.,Comml., & HRD),TSTRANSCO vide Regd. No.630, Dated:15.02.2024.

BY ORDER AND IN THE NAME OF TRANSMISSION CORPORATION OF TELANGANA LIMITED

**Sd/-
S.A.M. RIZVI, IAS
CHAIRMAN & MANAGING DIRECTOR (FAC)**

To,
The Chief Engineer, Construction, TSTRANSCO, Vidyut Soudha, Hyderabad.

Copy to:

The Chairman & Managing Director, TSSPDCL, Corporate Office, Hyderabad.
The Chairman & Managing Director, TSNPDCL, Nakkalagutta, Hanamkonda, Warangal.
The Chief Engineer, Power systems, TSTRANSCO, Vidyut Soudha, Hyderabad
The Chief Engineer, Transmission, TSTRANSCO, Vidyut Soudha, Hyderabad
The Chief Engineer, Metro Zone, TSTRANSCO, Hyderabad..
The Chief Engineer, Rural Zone, TSTRANSCO, Hyderabad..
The Chief Engineer, Warangal Zone, TSTRANSCO, Warangal..
The Chief Engineer, Karimnagar Zone, TSTRANSCO, Karimnagar.
The Chief Engineer, Telecom, TSTRANSCO, Vidyut Soudha, Hyderabad
The Chief Engineer, P & MM, TSTRANSCO, Vidyut Soudha, Hyderabad.
SE/T to Chairman & Managing Director, TSTRANSCO, Vidyut Soudha, Hyderabad
PS to the Joint Managing Director, Fin, Comml & HRD, TSTRANSCO, VS, Hyderabad
DE/T to Director, Transmission, TSTRANSCO, Vidyut Soudha, Hyderabad
DE/T to Director, Projects, TSTRANSCO, Vidyut Soudha, Hyderabad
ADE/T to Director, Lift Irrigation Schemes, TSTRANSCO, Vidyut Soudha, Hyderabad.
AE/T to Director Grid Operation, TSTRANSCO, Vidyut Soudha, Hyderabad
The FA & CCA (Accounts & CFO), TSTRANSCO, Vidyut Soudha, Hyderabad
Central Record Section – 2 copies.

// FORWARDED BY ORDER //

ASSISTANT DIVISIONAL ENGINEER