

TSTRANSCO Transmission Losses for the month of September 2016

EBC Data

INPUT		NET ENERGY in MU	OUTPUT		
			DISCOM	MU	
TSGENCO	TOTAL	1213.80	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1010.01	TSSPDCL	2805.04	
	HYDEL	203.79	TSNPDCL	1137.18	
C.G.S			Total	3942.22	
	CGS (Injection at TS-Periphery)	2466.19			
CPPs	TOTAL	124.47			
	132KV My Home Cements I & II	15.16			
	HWP	3.10			
	Kesoram	0.00			
	NBFA # 1 & 2	25.50			
	Sitapuram Power Limited	7.47			
	Madhucon SPIL 132 kV Kusumanchi	3.87			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	12.22			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	0.00			
	Krishnaveni sugars	6.14			
	132KV Laxmi Tulasi	2.60			
	Orient Cement 132 kV	0.01			
	NBEIL #1	20.34			
	NBEIL #2	20.34			
	ICL (Rassi Cements)	7.72			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	0.00			
Non-Conventional (132 Kv PDs)	TOTAL	59.82			
	Clean solar	1.93			
	Dayakara Solar (P) Ltd.	2.80			
	Enrich (Solar)	5.13			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.07			
	Grahati Solar	2.98			
	Kakatiya Cement & Sugar Industries Ltd.	-0.11			
	Karvy solar	0.94			
	My Home Power Ltd. (NGPL)	0.00			
	Mytrah Vayu (Godavari) Pvt. Ltd. (Wind)	17.63			
	NTPC Solar power plant (10MW)	0.95			
	Nizam Deccan Sugars Ltd.	0.00			
	Polepally Solar Park	2.79			
	Renue Akshay Solar Plant	9.56			
	SLS Power Corp. Ltd.	6.23			
	Shravana Power Projects Pvt. Ltd.	-0.02			
	Sunborne Energy Tech. (P) Ltd. (Solar)	4.69			
	Win solar	1.83			
	Renew Solar Plant (Mdk. Dist.)	2.62	Losses	MU	%
IPPs	Singareni Thermal Power Project Ltd. (Jaipur)	207.88	With in State	129.94	3.19
	TOTAL INPUT	4072.16	Total Losses	129.94	3.19

* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th October 2016 to 24.00'hours of 25th November 2016

* The Transmission Losses are worked out by using MRI data.

* MRI Data considered is from 00.00 Hr of 1st September 2016 to 24.00 Hr of 30th September 2016 at 00.30 Hr interval.

* The SR Losses (External Losses to TSTRANSCO) for the month of September 2016 is 2.268%

* Cumulative losses at TS-Periphery FY 2016-17 is 3.39 %